



KERALA WATER AUTHORITY

Telephone:0484-2623576
email:-qcldaluva@gmail.com



TC-12119

QUALITY CONTROL DISTRICT LAB,ALUVA -683101

WATER TEST REPORT

ULR NO:TC955224000024546F

Report Issue Date: 12.06.2024

Customer Name &Address	Date of Receipt of Payment	29.05.24
Mar Gregarious English Medium School	Date of Sample received	01.06.24
	Sample given by	Health Supervisor, North Paravoor Municipality
	Sample Code	ALY/S/17330/5/24
	Sample Name	Drinking Water
	Sample Condition	Good
	Source of Sample	Well
	Sample Quantity	2 Litre
Test performing dates :		From : 10.06.24 to 11.06.24

SL.N	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Turbidity	NTU	IS 3025 (Part10)-2023	1.0	1.01
2	pH at 25°C	-	IS 3025 (Part 11)-2022	6.5 to 8.5	6.55
3	Total Hardness (as CaCO3)	mg/L	IS 3025 (Part21)-2009(Reaffirmed 2019)	200	26.5
4	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-1988(Reaffirmed 2019)	250	11.5
5	Iron (as Fe)	mg/L	IS 3025 (Part 53)-2003 (Reaffirmed 2019)	1	0.31
6	Nitrate (as NO3)	mg/L	APHA 23rd Edition(UV Screening Method) 2017	45	4.69
7	Electrical conductivity at 25°C	micromhos/cm	IS 3025 (Part 14)-2013(Reaffirmed 2019)	-	59

Remarks:- DL : Detectable Limit
BDL : Below Detectable Limit


- NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .
2) The samples retain for 15 days from the end date of analysis
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Authorized By

End of Report

QUALITY MANAGER
KWA, QUALITY CONTROL DISTRICT LAB
ERNAKULAM

KWA/QCDL/ALY/01-2020	Issue Date : 04.10.2020
Rev No: 02	Rev.Date: 30/07/2023
	Page 1 of 1





Telephone:0484-2623576
email:-qcldaluva@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB,ALUVA -683101
WATER TEST-BACTERIOLOGY REPORT

Report No: ALY/B/5033

Report Issue Date: 12.06.2024

Customer Name &Address		Date of Receipt of Payment	29.05.24	
Mar Gregarious English Medium School		Date of Sample received	01.06.24	
		Sample given by	Health Supervisor, North Paravoor Municipality	
		Sample Code	ALY/B/5033	
		Sample Name	Drinking Water	
		Sample Condition	Good	
		Source of Sample	Well	
		Sample Quantity	200ml	
		Test performing dates :		From : 03.06.24 to 04.06.24
Sl. No.	Parameter	Acceptable Limit as per IS 10500-2012	Test Method	Result
1	Total Coliform	Shall not be Detected/100ml	IS15185-2016	Absent
2	E-Coli	Shall not be Detected/100ml	IS15185-2016	Absent

NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .

2) The samples retain for 15 days from the end date of analysis

3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Authorized By

End of Report

KWA/QCDL/ALY/01-2020		Issue Date: 01.06.2020	
Rev No: 01	Rev,Date : 02/06/2021	Page 1 of 1	QUALITY MANAGER KWA, QUALITY CONTROL DISTRICT LAB ERNAKULAM

